

Introduced: Mr. Jordan  
1<sup>st</sup> Reading: September 27, 2010  
Passed: October 11, 2010  
Posted: October 12, 2010  
Effective: October 21, 2010

RESOLUTION NUMBER 1071

A RESOLUTION TO NEGOTIATE THE PURCHASE OF A CATHODIC PROTECTION SYSTEM FOR THE UNDERGROUND GASOLINE STORAGE TANK AT THE GREENBELT POLICE FACILITY FROM J. D. RELLEK CO., INC., OF GLEN BURNIE, MARYLAND, AT A COST OF \$11,350

---

WHEREAS, the underground gasoline storage tank at the Greenbelt Police Facility is 21 years old and replacement of the tank is estimated to cost over \$100,000; and

WHEREAS, the tank failed its annual inspection by the Maryland Department of the Environment in March 2010 because it was determined the tank and piping are not properly cathodically protected; and

WHEREAS, the life of the existing tank can be extended by purchasing and installing a cathodic protection system; and

WHEREAS, a Request for Proposal for this work was sent to three firms; and

WHEREAS, J. D. Rellek Co. Inc. of Glen Burnie, Maryland, submitted the lowest quote to do the work; and

WHEREAS, the J. D. Rellek Company is certified to provide corrosion specialty service and the work will be done by Maryland Department of the Environment qualified technicians. NOW, THEREFORE,

BE IT RESOLVED by the Council of the City of Greenbelt, Maryland, that the City Manager be authorized to execute a contract with J. D. Rellek Co. Inc. of Glen Burnie, Md. to perform repairs to the underground gasoline tank at the Police Station at a cost of \$11,350 in accord with its Proposal Number 082710-3 dated August 27, 2010.

PASSED by the Council of the City of Greenbelt, Maryland, at its regular meeting of October 11, 2010.

\_\_\_\_\_  
Judith F. Davis, Mayor

ATTEST:

\_\_\_\_\_  
Cindy Murray, City Clerk